


CFMEU SAFETY GUIDANCE

WESTERN AUSTRALIA

How to Build a Mobile Scaffold



Install components as shown in the picture above

REPORT UNSAFE WORK PRACTICES - CALL (08) 9228 6900 OR EMAIL SAFETY@CFMEUWA.COM

Stand up. Speak out. Come home.

Authorised by Mick Buchan, State Secretary, CFMEU WA, 80 Beaufort St Perth

CFMEU SAFETY GUIDANCE

WESTERN AUSTRALIA

Mobile Scaffold Checklist

Inspection Criteria	Date							Subcontractor	Signature
	Tick	Tick	Tick	Tick	Tick	Tick	Tick		
Handrail at correct height									
Midrail at correct height									
Kickboard fitted									
Deck placed at suitable working height									
Diagonal bracing in place per diagram									
Plan brace in per diagram									
Castor locking wheels operational									
Internal ladder is appropriate for the size of scaffold									
Internal ladder extends through the working deck									
Internal ladder fixed at base									
A hinged access door is fitted to the working deck									
Mobile scaffold standing on firm level surface									
All components are of the same make and type									

If any of the criteria above can't be ticked off or any of the components are damaged tag the scaffold out of service and report it to your supervisor – Do not work off non-compliant or damaged scaffold

REPORT UNSAFE WORK PRACTICES - CALL (08) 9228 6900 OR EMAIL SAFETY@CFMEUWA.COM

Stand up. Speak out. Come home.